

Our Ref: NJ/M120269
Test Report: M105277



6th November 2012

SMC Co.,Ltd
642-17 Gahyeon-ri
Tongjin-eup
Gimpo-city
Gyeonggi-do
Korea

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

GLASS REINFORCED PLASTICS (GRP) – COMPONENTS

5120

GRP Panel . Beige coloured, hot press moulded GRP panel. For use with water up to 40°C.

APPROVAL NUMBER: 1206555

The Scheme reserves the right to review approval. This approval is valid between June 2012 and June 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason', is written over a light blue horizontal line.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme Ltd.
30 Fern Close, Pen-y-Fan Industrial Estate,
Oakdale, Gwent NP11 3EH, UK.
Tel: 01495 248454. Fax: 01495 236289.
E-mail: info@wras.co.uk Website: www.wras.co.uk

The Water Regulations Advisory Scheme Ltd
Registered in England No. 06463220
Registered Office: 1 Queen Anne's Gate,
London SW1 199T